

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
SAN FRANCISCO BAY REGION

ORDER NO. 77-57

NPDES PERMIT NO. CA0037486

AN ORDER AMENDING ORDER NO. 74-187
TO ADOPT AMENDED WASTE DISCHARGE
REQUIREMENTS FOR

MONTARA SANITARY DISTRICT
SAN MATEO COUNTY

The California Regional Water Quality Control Board, San Francisco Bay Region,
(hereinafter called the Board) finds that:

1. The Board, on December 17, 1974, adopted Order No. 74-187 (NPDES Permit No. CA0037486) prescribing waste discharge requirements for Montara Sanitary District, hereinafter called the discharger.
2. The discharger currently discharges a secondary effluent to the Pacific Ocean. The discharger does not meet other effluent and receiving water limitations, including certain discharge prohibitions and provisions of Order No. 74-187. The discharger plans to comply by participation in the San Mateo County Mid-Coastside Wastewater Management Plan (SAM), which is expected to be completed in July 1979.
3. The Board, on March 15, 1977, adopted Cease and Desist Order No. 77-21 prescribing a time schedule for compliance with Order No. 74-187.
4. This project involves the continued operation of a publicly-owned facility to provide sewerage service with negligible or no expansion of use beyond that previously existing. Consequently, this project will not have a significant effect on the environment based upon the exemption provided in Section 15101, Title 14, California Administrative Code.
5. The Environmental Protection Agency has modified the definition of secondary treatment to exclude limitations on effluent fecal coliform bacteria.
6. The Board has notified the discharger and interested agencies and persons of its intent to prescribe revised requirements.
7. The Board, in a public meeting, heard and considered all comments pertaining to this discharge.

IT IS HEREBY ORDERED THAT Order No. 74-187 be amended as follows:

1. Effluent Limitation A.1 shall hereafter read:

"The discharge of an effluent containing constituents in excess of the following limits is prohibited:

<u>Constituents</u>	<u>Units</u>	<u>30-Day Average</u>	<u>7-Day Average</u>	<u>Maximum Daily</u>	<u>Instan- taneous Maximum</u>
a. Chlorine Residual	mg/l	-	-	-	0.0
b. BOD	mg/l	30	45	60	-
	lbs/day	250	375	500	-
	kg/day	113	170	226	-
c. Suspended Solids	mg/l	30	45	60	-
	lbs/day	250	375	500	-
	kg/day	113	170	226	- "

2. Provision D.4 shall hereafter read:

"The discharger shall review and update annually its contingency plan as required by Board Resolution No. 74-10. The discharge of pollutants in violation of this Order where the discharger has failed to develop and/or implement a contingency plan will be basis for considering such discharge a willfull and negligent violation of this Order pursuant to Section 13387 of the California Water Code."

3. Provision D.9 shall hereafter read:

"This Order expires January 1, 1980, and the discharger must file a Report of Waste Discharge in accordance with Title 23, California Administrative Code, not later than 180 days in advance of such date as application for issuance of new waste discharge requirements."

4. Provision D.11. is added to read as follows:

"The discharger shall fully comply with the terms and conditions of this Board's Cease and Desist Order No. 77-21."

I, Fred H. Dierker, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, San Francisco Bay Region on June 21, 1977.

FRED H. DIERKER
Executive Officer